



NOTES:

1. Residential subdivision water services to be installed by developer.
2. Copper pipe to be American or Canadian made type K.
3. Corporation and curb stops to be flared fittings. Curb stops shall have lock wing fixtures. Corporation stop to be installed with key sideways in open position.
4. Water meter to be obtained from City.
5. Service saddle to be installed no less than 18-inches from pipe joint.
6. Wherever possible service line to extend perpendicular from the watermain to the meter stop.
7. All meter boxes located in driveways and sidewalks shall have traffic covers.



City Of Beaverton

ENGINEERING DEPARTMENT

1" COPPER SERVICE CONNECTION

UTILITIES ENGINEER
David A. Winship, P.E.

DATE
6 - 10 - 04

DRAWN BY
CDH - WD

DRAWING NO.
640